


FA & PA LEGEND :-

SYMBOL	DESCRIPTION	QTY.
	MULTI SENSOR DETECTOR ABOVE FALSE CEILING	17
	MULTI DETECTOR BELOW FALSE CEILING	00
	HEAT DETECTOR BELOW FALSE CEILING	02
	MANUAL CALL POINT @HEIGHT OF 1310 MM FROM FF. LVL.	01
	HOOTER CUM STROBE @HEIGHT OF 2100 MM FROM FF. LVL.	01
	CONTROL MODULE @HEIGHT OF 2400 MM FROM FF. LVL.	02
	MINI MONITOR MODULE FOR FLOW SWITCH @HEIGHT OF 2400 MM FROM FF. LVL.	03
	RELAY MODULE FOR 3RD PARTY INTEGRATION @HEIGHT OF 2400 MM FROM FF. LVL.	00
	FIRE FIGHTER'S TELEPHONE JACK @HEIGHT OF 1310 MM FROM FF. LVL.	01
	FAULT ISOLATOR MODULE ON FALSE CEILING	00
	2 WATT CEILING MOUNT SPEAKER	01
	2 WATT WALL MOUNT SPEAKER	00
	MAIN FIRE ALARM PANEL	01
	MAIN PA CONSOLE	01
	FIRE REPEATER PANEL	00
	16 AMP UPS POWER POINT	02
	2 CORE 1.5 Sqmm FRLS CABLE FOR FIRE LOOP (APROX. RM.)	__ __ Mtr
	2 CORE 1.5 Sqmm FRLS CABLE FOR 24V DC (APROX. RM.)	__ __ Mtr
	2 CORE 1.5 Sqmm FRLS CABLE FOR FFT JACK (APROX. RM.)	__ __ Mtr
	2 CORE 1.5 Sqmm FIRE CABLE PA SPEAKER ZONE (APROX. RM.)	__ __ Mtr
	24DC POWER SUPPLY	01
	6 AMP UPS POWER POINT	01

- NOTE:
- All dimensions are in inches.
 - All levels are in inches.
 - This drawing is a copyright and property of the architect, is not to be produced, copied, handed over to third party or used for any other purpose other than for which it is intended.
 - This drawing is to be read and not to be scaled.
 - All dimensions shall be verified on site prior to start of work any discrepancy shall be brought to the notice of the Architect.
 - The Contractor / Project Manager must check all dimensions and details and be responsible for the same. Any discrepancy shall be notice of the Architect.
 - This drawing shall be read in conjunction with all relevant architectural, structural and services drawings. Any discrepancy noticed shall be brought to the attention of the consultants and resolved as soon as possible, but always prior to procurement / execution of works.
 - All the services ducts / cut-outs are to be covered after services provisions.
 - Drawing approval is for the conformity with outline design intent and does not relieve the contractor/ subcontractor from full responsibility for the accuracy, integration and fitness for purpose of design.
 - Construction Manager/Project Manager to revert back within 7 working days of receiving the drawings on coordination and construction issues. If otherwise it would be deemed that they have understood and accepted the drawing/design and own full responsibility for the works carried out accordingly.

NOTES:

Rev.	Purpose	Date

PROJECT:

RESIDENCE

SITE:

KAROL BAGH

CLIENT:

MR. AJAY GOYAL

PRINCIPAL DESIGN CONSULTANT:

F WORLD

STATUS :

GFC

DRAWING TITLE:

FIRE ALARM LEGEND SHEET

DRAWN BY :		CHECKED BY :	
DRAWING NO :	REV NO :	SCALE:	
FA_02		NTS	